सत्यमेव जयते

Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Purulia Fire Station, Ranchi Road,Purulia, Pin:- 723101

Memo No.: FSR/IND/WB/FES/20192020/55218 **Date : 31-05-2024**

From :
Divisional Fire Officer
Purulia Division,
West Bengal Fire & Emergency Services

To :
Nirmala Chitta Teachers Training Institute
Vill: Pabra(Paharigora),P.O: Tentulhity,P.S: Santaldih,Dist:Purulia,Pin:723155

Sub : Renewal of Fire Safety Certificate for the occupancy of an existing construction of G+2 storied building under the group educational in favour of Dibakar Memorial Public Institution at the premises No: Nil, Vill: & Mouza: Pabra, Plot No: 1673, J.L. No: 57,P.O: Teltulhity , P.S: Santaldih, Dist: Purulia, Pin: 723155.

Memo No.: FSR/IND/WB/FES/20192020/55218

This is in reference to your AIN 211912406300000472 dated 11-May-2024 regarding Renewal of Fire Safety Certificate for the occupancy of an existing construction of G+2 storied building under the group educational in favour of Dibakar Memorial Public Institution at the premises No: Nil, Vill: & Mouza: Pabra, Plot No: 1673, J.L. No: 57,P.O: Teltulhity , P.S: Santaldih, Dist: Purulia, Pin: 723155. .

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. 2. No parking shall be allowed on the driveway. 3. Existing electrical wiring of the whole building shall be carefully checked in view of fire and life safety. 4. The teaching, nonteaching and security staff shall be

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300000472

knowledgeable about the installed firefighting equipment of the building and operate it in the event of fire and testing. 5. Mock fire practice and evacuation drills shall be performed periodically with the participation of all occupants of the buildings. 6. Switchgear room shall be protected with CO2 or DCP fire extinguishers which are conforming to I.S. specifications. 7. A crew of trained firefighting under the experienced officer shall be maintained around the clock for the safety of the building. 8. The arrangement shall be made for regular checking and testing for all the fire safety fixed installations and equipment in the buildings to keep perfectly good working conditions at all times. 9. The fire safety audit is to be conducted at regular intervals and to be recorded in the fire prevention maintenance on the register. 10. Fire notice for firefighting and evacuation of the building shall be prepared and displayed in all vulnerable places of the building. 11. Any deviation and changes in the nature of the use of the building in respect of the submitted plan drawing without obtaining prior permission from the office, and the renewal of the fire safety certificate shall be treated as cancelled. 12. This renewal fire safety certificate is valid for 03(three) years and has to be renewed every three (03) years from the date of issue of this letter. 13. This certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding the performance of all the Fire Safety arrangements and installation of this building.

Valid Upto : 30-May-2027

Memo No.:
FSR/IND/WB/FES/20192020/55218

Signature Not Verified

Digitally Signed.
Name: PLABAN MODAK
Date: 31-May-2024 13:25:15
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300000472